Montana Department of Environmental Quality - Thompson River Co-Gen, LLC, Permit #3175-03



Permit #3175-03 Modification Presentation

- Applicable Permit History
- Boiler Oxides of Nitrogen (NOx) Emissions
- Boiler Sulfur Dioxide (SO₂) Emissions
- Other Permit Modifications
- Thompson Falls Area Ambient Air Quality Impact Analysis

Permit History – Comparison * Permit #3175-02 was an administrative action

Applicable Permit Term	Permit #3175-00	Permit #3175-01	Permit #3175-03	
PM ₁₀ Emission Limit/Control	0.017 gr/dscf	0.017 gr/dscf	0.017 gr/dscf	
NOx Emission Limit/Control	0.220 lb/MMBtu	0.178 lb/MMBtu	0.178 lb/MMBtu	
SO ₂ Emission Limit/Control	0.300 lb/MMBtu	0.220 lb/MMBtu	0.206 lb/MMBtu	
CO Emission Limit/Control			0.259 lb/MMBtu	
VOC Emission Limit/Control			0.0308 lb/MMBtu	

Boiler Oxides of Nitrogen (NOx) Emissions

Applicable Permit Term	Existing Permit Term	TRC Proposed Permit Term	Draft Permit Term	
NOx BACT Emission Limits	0.178 lb/MMBtu (1-hr average)	0.28 lb/MMBtu (30-day rolling average)	0.178 lb/MMBtu (3-hr average)	
Short-Term NOx Emission Limits	34.32 lb/hour 195 lb/hour (1-hr average)		47.24 lb/hr (1-hr average)	
NOx BACT Control Strategy	Combustion Control (CC): Over-Fire Air (OFA)	CC/OFA	Selective Non- Catalytic Reduction Unit (SNCR) and CC/OFA	

Boiler Sulfur Dioxide (SO₂) Emissions

Applicable Permit Term	Existing Permit TRC Proposed Permit Term		Draft Permit Term	
SO ₂ BACT Emission Limits	0.220 lb/MMBtu (1-hr average)	0.275 lb/MMBtu (30-day rolling average)	0.206 lb/MMBtu (30-day rolling average)	
SO ₂ Short-Term Emission Limits	42.42 lb/hr (1-hr average)	155 lb/hr (1-hr average)	72.30 lb/hr (1-hr average)	
SO ₂ Percent Reduction	90%	Remove Term	Remove Term	
SO ₂ BACT Control Strategy	Dry-Lime Scrubber (Specific FGD)	Flue Gas Desulfurization Unit (FGD)	FGD	
SO ₂ Monitoring Strategy	Periodic Source Testing	Periodic Source Testing	SO ₂ CEMS	

Other Permit Modifications

Applicable Permit Term	Existing Permit Term	TRC Proposed Permit Term	Draft Permit Term	
Boiler Heat Input Limit	192.8 MMBtu/hr (1- hr avg.) and 1,688,928 MMBtu/year (rolling 12-month avg.)	1,688,928 MMBtu/year (rolling 12-month avg.)	192.8 MMBtu/hr (3- hr avg.) and 1,688,928 MMBtu/year (rolling 12-month avg.)	
Boiler Steam Production Limit	130,000 lb steam/hr	Remove Limit	Remove Limit	
Boiler Baghouse 40,513 dscfm Air-Flow Limit		Remove Limit	Remove Limit	

Additional Slides

Modeled Ambient Air Quality Impacts

NAAQS/MAAQS Compliance Demonstration

Pollu- tant	Avg. Period	Modeled Conc. ^a (μg/m³)	Total (w/bkgd) (μg/m³)	NAAQS (μg/m³)	% of NAAQS	MAAQS (μg/m³)	% of MAAQS
PM ₁₀	24-hr	106 ^b	136	150	91	150	91
	Annual	31.3 ^b	39.3	50	79	50	79
NO ₂	1-hr	214 ^c	289			564	51
	Annual	3.4 ^d	9.4	100	9.4	94	10
SO ₂	1-hr	433	468			1,300	36
	3-hr	180	206	1,300	16		
	24-hr	73	84	365	23	262	32
	Annual	5.1	8.1	80	10	52	16


^a Concentrations are high-second high values except annual averages.

^b Includes TRC and TRL impacts (from Rev. 7, July 30, 2004).

^c The ozone limiting method has been applied to this result.


^d The ambient ratio method has been applied to this result.


TRC Modeling Domain Topography




Details of Modeling


- Objective: to predict the worst-case impacts
- Model uses wind speed, direction, temperature and cloud cover
- Modeled 10 years of Meteorological Data, 88,000 hours of data
- Data from Missoula and Kalispell






TRC Modeling Domain Showing Modeled Annual SO2 Impacts







Public Comment Permit #3175-03

- Written comments must be received by March 13,
 2006
- Attention: M. Eric Merchant
 Department of Environmental Quality
 Air Resources Management Bureau
 P.O. Box 200901
 Helena, MT 59620-0901
- emerchant@mt.gov
- Fax (406) 444-1499 Attention: M. Eric Merchant